

NOTES:

1. UPON ACWWA APPROVAL A FIRE HYDRANT MAY BE USED AS AN ALTERNATE BLOW-OFF. SEE DETAIL W-10.
2. ALL METAL SURFACES SHALL BE COATED WITH TWO COATS OF LIQUID EPOXY, 16 MIL DRY FILM THICKNESS IN ACCORDANCE WITH AWWA C210.