

PFAS TESTING RESULTS

ACWWA is committed to providing safe, high-quality water that meets all state and federal regulations. We continue to work with the Colorado Department of Public Health and Environment (CDPHE) to understand how future EPA regulations for PFAS will be implemented in Colorado. In 2023, ACWWA has committed to PFAS sampling/testing once per quarter to ensure we communicate updates to our customers, develop mitigation strategies, and evaluate available funding options.

2024 Sampling Data	Contaminant=		PFOA	PFOS	PFNA	PFHxS	PFBS	HFPO-DA
	EPA Proposed MCL=		4ppt	4ppt	Hazard Index	Hazard Index	Hazard Index	Hazard Index
Date	Entry Points and other Source	Analysis Method=	533	533	533	533	533	533
3/7/2024	Joint Water Purification Plant		3.2ppt	<1.9ppt	<1.9ppt	<1.9ppt	3.9ppt	<1.9ppt
2/22/2024	Joint Water Purification Plant		2.8ppt	<2ppt	<2ppt	<2ppt	3.4ppt	<2ppt
1/25/2024	Joint Water Purification Plant		3ppt	<1.9ppt	<1.9ppt	<1.9ppt	4.9ppt	<1.9ppt

GLOSSARY OF ACRONYMS

ppt= Concentration in parts per trillion. 1 ppt is equal to 1 ng/L (nanogram per liter)