



**Arapahoe County Water and Wastewater Authority**  
13031 E Caley Avenue, Centennial, CO 80111 9364  
Phone (303) 790-4830, Fax (303)790-9364

---

**Utility Report**

A utility report is only needed if a main line extension is required. It's highly recommended a flow/pressure test is performed. ACWWA uses the AWWA M22 Manual for meter sizing which has a pressure component. Currently we use the upper value from the pressure range in ACWWA's master plan unless a pressure test is performed by a third party and that data provided along with the meter sizing calculations.